

CAVIUS


MAINTENANCE SCHEDULE

PRODUCT NAME: CAVIUS 10 Year Photoelectric Smoke Alarm

PRODUCT CODE: CAV10

PRODUCT CERTIFICATION: AS3786, EN14604

PRODUCT IMAGE:



LOW BATTERY INDICATOR: A short acoustic “beep” will sound when the battery is near its end of life. In this stage it will continue for a maximum of 30 days. You must change the smoke alarm after 10 years usage, or if the smoke alarm has suffered any damage.

ALL SMOKE ALARMS HAVE AN EXPIRY DATE, PLEASE CHECK ON THE BACK OF THE ALARM.

MAINTENANCE: The smoke alarm should be vacuumed cleaned once per month, and it can be wiped with a damp cloth (do not open the alarm). Test the smoke alarm once per month by pushing the test button, the smoke alarm should give a loud alarm tone.



For further information, please refer to the User Guide, which can be found on www.cavius.co.nz