

# CAVIUS

## MAINTENANCE SCHEDULE

**PRODUCT NAME:** CAVIUS 10 Year Thermal Heat Alarm

**PRODUCT CODE:** CAVTH10

**PRODUCT CERTIFICATION:** EN60065

**PRODUCT IMAGE:**



(3002 model)



(3004 model)

**LOW BATTERY INDICATOR:** A short acoustic “beep” will sound when the battery is near its end of life. In this stage it will continue for a maximum of 30 days. You must change the thermal heat alarm after 10 years usage, or if the alarm has suffered any damage.

**ALL THERMAL HEAT ALARMS HAVE AN EXPIRY DATE, PLEASE CHECK ON THE BACK OF THE ALARM.**

**MAINTENANCE:** The thermal heat alarm should be tested once per month by pushing the test button. The thermal heat alarm should give a loud alarm tone.

For further information, please refer to the Instruction Manual, which can be found on [www.cavius.co.nz](http://www.cavius.co.nz)