

CAVIUS

MAINTENANCE SCHEDULE

PRODUCT NAME: CAVIUS Wireless Family Photoelectric Smoke Alarm

PRODUCT CODE: CAV5WF

PRODUCT CERTIFICATION: AS3786:2014

PRODUCT IMAGE:



LOW BATTERY INDICATOR: Inside the batter chamber is a 5 Year Lithium CR123A replaceable battery. A short acoustic “beep” will sound when the battery is near its end of life. In this stage, it will continue for a maximum of 30 days. You can replace the battery with another 5 Year Lithium CR123A battery. After 10 years or at the expiry date printed on the product label you must replace the smoke alarm, or if the smoke alarm has suffered any damage.

ALL SMOKE ALARMS HAVE AN EXPIRY DATE, PLEASE CHECK ON THE BACK OF THE ALARM.

MAINTENANCE: The smoke alarm should be vacuumed cleaned once per month, and it can be wiped with a damp cloth (do not open the alarm). Test the smoke alarm once per month by pushing the test button, the smoke alarm should give a loud alarm tone.



TESTING: Press the test button on any alarm for at least 6.5 seconds (count 2 sets of 3 sound sweeps). This will send out a test signal from the alarm; all other connected alarms should receive the signal within a short time

The alarms will respond in either two ways:

1. A single beep every 8 seconds indicates that the alarms are connected and functioning.
2. Three short beeps every 8 seconds indicates a smoke sensor fault. The alarm should be cleaned by running the vacuum (on a low setting) around the smoke alarm chamber and tested again. If required this indication can be stopped early on each alarm by a short press of the test button.

For further information, please refer to the User Guide, which can be found on www.cavius.co.nz